

ADDENDUM No: 1

STATE OF OREGON DEPARTMENT OF ADMINISTRATIVE SERVICES

August 2nd, 2019

ITB NO: DASPS-1542-19

PROJECT: Secretary of State BSD Office Addition

BID CLOSING DATE: August 8th, 2019 / NOT LATER THAN 2:00 PM

This Solicitation Addendum is issued to the above referenced bid and forms a part of the contract documents and modifies the original scope of work, specifications and drawings, requirements and deadlines. Except as changed by this Addendum, all terms, conditions, scope of work, plans, specification, requirements and deadlines in the original ITB and previous addenda remain unchanged.

This Solicitation Addendum must be acknowledged by inserting its number on the appropriate blank lines in Section H – Addenda Acknowledgement of the Invitation to Bid. Failure to do so may result in rejection of Bid.

Requests for clarification, requests for change, and protests of Solicitation Addendum provisions addressed in this Solicitation Addendum must be received by DAS by 2:00 PM (Pacific Time) on August 5th, or they will not be considered. DAS will not consider requests or protests of matters not added to or modified by this Solicitation Addendum.

New language is indicated by **bold print and underline**, deleted language is indicated by brackets [].

1	Addition	Adding the most recent PWR language in SECTION E - BOLI PREVAILING WAGE RATE REQUIREMENTS, E.2. Prevailing Wage Rate for Public Works in Oregon effective July 1, 2019
2	Modified	CHANGES TO DRAWINGS: 3.01 DRAWING E1.31 - ELECTRICAL FLOOR PLANS A. <u>In Office 158, Installation of the new 1kw heater will require tapping into the power circuit ahead of the relay located in the electrical room. Control for this heater will be by wall mounted thermostat mounted near door. Thermostat control will be installed by DAS.</u>

End of Addendum 001