

**Travel Information Council**  
1500 Liberty St. SE, Suite 150  
Salem, Oregon 97302  
503-378-4508 1-800-574-9397  
503-378-6282 FAX



Kate Brown, Governor

## ITB 2018-002 Northbound & Southbound Oak Grove Safety Rest Area Rest Room Replacements Addendum 2

DATE: December 7, 2018

REGARDING:

### **1- DETAIL 1/A501 – ROOFING – ROOF SHEATHING DETAIL 1/A501**

Use maximum of ½” plywood or OSB roof sheathing under roofing as shown, but not labeled, in Detail 1/A501 as required by roofing manufacturer. Fasten to wood substrate as required by roofing manufacturer with fasteners which will not be exposed on the underside of the underlying decking.

### **2- SECTION 07 4213 – METAL WALL PANELS**

In Attachment A – Specifications, in addition to the manufacturers listed, the following manufacturer and products are approved: Taylor Metal Classic 7/8” Corrugated 24ga.

### **3- SECTION 07 6100 – SHEET METAL ROOFING**

In Attachment A – Specifications, in addition to the manufacturers listed, the following manufacturer and products are approved: Taylor Metal Versa Span 1-3/4” 12” 24ga.

### **4- SECTION 08 1113 – HOLLOW METAL DOORS AND FRAMES**

In Attachment A – Specifications, in addition to the manufacturers listed, the following manufacturer is approved: Stiles Custom Hollow Metal.

### **5- SECTION 10 2800 – TOILET, BATH, AND LAUNDRY ACCESSORIES – HAND DRIERS**

In Attachment A – Specifications, in addition to the manufacturers listed, the following manufacturer and products are approved: Saniflow Corp. Speedflow Plus M17