

**Travel Information Council**  
1500 Liberty St. SE, Suite 150  
Salem, Oregon 97302  
503-378-4508 1-800-574-9397  
503-378-6282 FAX



Kate Brown, Governor

## ITB 2018-002 Northbound & Southbound Oak Grove Safety Rest Area Rest Room Replacements Addendum 5

DATE: January 4, 2018

REGARDING: ATTACHMENT B DRAWINGS – NB CIVIL PLANS

### **1- SHEET C2-NB – DEMOLITION PLAN**

Add the following to Note 14:

The abandoned 10,000 gallon 2-compartment cast-in-place concrete tank (overall tank measurements are 23'6"x11'x7'2" with 9"-wall thickness with #3 rebar 8" O.C.) was "abandoned" per Oregon DEQ requirements and that the top was broken, the tank pumped free of septage, and filled with bar-run gravel or sand.

The tank needs to be removed before building your new foundation partially over it. Dewatering may be required in deep excavation areas and structural fill shall be placed to finished grade.

### **2- SHEET C4-NB – PAVING & GRADING PLAN**

Replace with updated drawing Sheet C4-NB.

REGARDING: ATTACHMENT B DRAWINGS – SB CIVIL PLANS

### **3- SHEET C4-SB – PAVING & GRADING PLAN**

Replace with updated drawing Sheet C4-SB.