

Travel Information Council
1500 Liberty St. SE, Suite 150
Salem, Oregon 97302
503-378-4508 1-800-574-9397
503-378-6282 FAX



Kate Brown, Governor

ITB 2018-002 Northbound & Southbound Oak Grove Safety Rest Area Rest Room Replacements Addendum 8

DATE: January 9, 2019

REGARDING: ATTACHMENT A - SPECIFICATIONS

1- SECTION 07 4213 – METAL WALL PANELS, PART 1 GENERAL, 1.05 WARRANTY

Delete paragraph B and replace with the following:

B. Correct defective Work within a one-year period after Substantial Completion, including defects in water tightness, integrity of seals, and for a 10-year period correct defective panel material.

2- SECTION 07 6100 – SHEET METAL ROOFING, PART 1 GENERAL, 1.06 WARRANTY

Delete paragraph C and replace with the following:

C. Provide 10-year manufacturer warranty for metal roofing and flashing. Warranty shall include degradation of metal finish and failure of watertightness or seals.

3- SECTION 09 9000 – PAINTING AND COATING, PART 2 PRODUCTS, 2.04 EXTERIOR DOOR FILM

Delete paragraph A and replace with the following:

A. 3M Scotchgard Surface Protection film 2200

REGARDING: ATTACHMENT B DRAWINGS – SB ARCHITECTURAL + STRUCTURAL

4- SHEET A101-SB – FLOOR PLAN

Added information pertaining to toilet stall doors

5- SHEET A501-SB– ARCHITECTURAL DETAILS, DETAIL 1 MAIN ROOF ASSEMBLY

Added callout for insulation

6- SHEET A601-SB – DOOR & WINDOW SCHEDULES

Added information pertaining to toilet stall doors

7- SHEET A602-SB – HARDWARE SCHEDULE

Added information pertaining to toilet stall doors

REGARDING: ATTACHMENT B DRAWINGS – NB ARCHITECTURAL + STRUCTURAL

8- SHEET A101-NB – FLOOR PLAN

Added information pertaining to toilet stall doors

9- SHEET A501-NB– ARCHITECTURAL DETAILS, DETAIL 1 MAIN ROOF ASSEMBLY

Added callout for insulation

10- SHEET A601-NB – DOOR & WINDOW SCHEDULES

Added information pertaining to toilet stall doors

11- SHEET A602-NB – HARDWARE SCHEDULE

Added information pertaining to toilet stall doors