



ALL CELLULAR DUCT CIRCUITS BELOW THIS AREA SHALL BE FED TO PANELS 2NB1 AND 2CB1 THE NORMAL AND ISOLATED GROUND PANEL.

ALL CELLULAR DUCT CIRCUITS BELOW THIS AREA SHALL BE FED TO PANELS 2NA1 AND 2CA1 THE NORMAL AND ISOLATED GROUND PANEL.

**NOTES THIS SHEET**

- 1 CONNECTION FOR UNDER COUNTER INSTANT HOT, 120V. COORDINATE CONNECTION WITH MECHANICAL.
- 2 MOUNT RECEPTACLE OUTLETS ABOVE COUNTER BACK-SPLASH FOR MICROWAVES OVEN. 20AMP, 120V.
- 3 120 VOLT RECEPTACLE OUTLET FOR REFRIGERATOR. COORDINATE EXACT LOCATION WITH OWNER.
- 4 120 VOLT RECEPTACLE OUTLETS FOR VENDING MACHINES. VERIFY LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- 5 PROVIDE 30 AMP RECEPTACLE OUTLET FOR ZEROX, 5100 AND 5065. RECEPTACLE NO. 60053277. COORDINATE RECEPTACLE WITH EXISTING EQUIPMENT PLUG PRIOR TO ROUGH-IN.
- 6 PROVIDE RECEPTACLE OUTLET FOR PAPER DRILL 208 VOLT, SINGLE PHASE. RECEPTACLE TO MATCH EXISTING PLUG. VERIFY PRIOR TO ROUGH-IN.
- 7 PROVIDE 10 FOOT PLUGMOLD WITH OUTLETS AT 12 FEET ON CENTER, MOUNT AT 48" ABOVE FINISHED FLOOR. WIREMOLD 2000 SERIES.
- 8 CONNECTION FOR POWER ASSISTED DOOR MOTOR, 120V. COORDINATE CONNECTION AND REQUIREMENTS WITH DOOR HARDWARE SUPPLIER.
- 9 PROVIDE CONNECTION TO KIOSK SHED ADJACENT TO THE BUILDING. COORDINATE EXACT KIOSK LOCATION AND POWER REQUIREMENTS. PRIOR TO ROUGH-IN.
- 10 PROVIDE A MULTI-SERVICE RECESSED FLOOR BOX. IT INCLUDES 4 WIRING COMPARTMENTS, ALLOWS FOR DOUBLE DUPLEX POWER AND DOUBLE LOW POTENTIAL CAPACITY. PROVIDE COMPLETE WITH RAK MIL FLUSH ACCESS HATCH WITH CARPET TRIM AND WIRE MANAGEMENT BLOCKS RECESSED ACTIVATION WALKER-BOX RESOURCE RFB.
- 11 PROVIDE CELLULAR DUCT AT THE CONFERENCE ROOM FLOOR AREA SIMILAR TO THE OPEN OFFICE SYSTEM. RUN TO WALL AND CONDUIT TO PANELS FOR POWER AND CONDUIT TO CEILING SPACE FOR DATA SYSTEM.
- 12 PROVIDE CONNECTION TO FOUR DECEIVES. 120 VOLT, 20 AMP EACH LOCATED IN AREAS 129, 139 AND 147. CONNECT TO PANELS 2NA2 AND 2NB2. COORDINATE EXACT LOCATION WITH OWNER.
- 13 PROVIDE RECESSED FLOOR BOX FOR A DUPLEX RECEPTACLE.

**Floor Plan - POWER**



Owner:  
**TKS Trust**

9950 SW Arctic Drive  
Beaverton, OR 97005

Project:  
**USFS BUILDING**

Sheet Title:  
**Floor Plan - POWER**

Revisions:  
4-15-96

MILDREN DESIGN GROUP, P.C. 1993. ALL RIGHTS RESERVED.  
 THESE DRAWINGS ARE THE PROPERTY OF MILDREN DESIGN GROUP, P.C. AND ARE NOT TO BE USED OR REPRODUCED IN ANY MANNER, EXCEPT WITH THE PRIOR WRITTEN PERMISSION OF MILDREN DESIGN GROUP, P.C.

Date: **March 5, 1996**  
 Drawn by: **CLL** Checked by: **HLB**  
 Job Number: **94174**  
 Sheet of:

PROJECT NO.: 95-564  
 5045 SW Lake Road, Milwaukie, Oregon 97128  
 INTERFACE ENGINEERING INC.  
 Consulting Engineers  
 30 99-044 URSAN 11.5A1111