

**Invitation to Bid  
DASPS-1473-18  
Solicitation Addendum No. 1**

---

This Solicitation Addendum modifies the Bid Document(s) for Work only to the extent indicated herein. All other areas not specifically mentioned or affected by this Solicitation Addendum shall remain in full force. This Solicitation Addendum shall be added as a part of the Original Bidding Document.

This Solicitation Addendum must be acknowledged by inserting its number on the appropriate blank lines in Section H of the Invitation to Bid, and by providing all required signatures prior to Bid Closing. Failure to do so may result in rejection of Bid.

=====

Requests for clarification, requests for change, and protests of Solicitation Addendum provisions addressed in this Solicitation Addendum must be received by DAS by **1:00 P.M.** (Pacific time) on **December 10, 2018**, or they will not be considered. DAS will not consider requests or protests of matters not added to or modified by this Solicitation Addendum.

=====

**1. MODIFICATIONS TO SPECIFICATIONS:**

1. NONE.

**2. MODIFICATIONS TO PLANS**

1. Sheet A2-1: ADD the following Note:

*Note: The walk-in cooler and freezer each contain a fire suppression system. The specific system will need to be deactivated, drained back (if required), heads removed (and saved for re-installation) and drops plugged prior to demolition. Once the new walk-in equipment is installed the sprinkler heads will need to be re-installed and the fire suppression system will need to be fully activated. The installed system will need to be tested and approved by the City of Albany.*

*This installation shall conform to each of the following:*

- 1. NFPA 13, 2013 Edition, Installation of Sprinkler Systems,*
- 2. International Building Code, 2014 Edition*
- 3. International Fire Code, 2014 Edition*
- 4. International Mechanical Code, 2014 Edition*
- 5. Underwriters Laboratories Fire Protection Equipment Directory, 2015 Edition*

*All work shall comply fully with all applicable codes and standards. Nothing in the contract documents shall be construed to permit non-compliance with any code or standard.*

*Warranty: The contractor shall guarantee all materials, equipment and workmanship in this installation for a period of one year from the date of completion. Any system failure during that time shall be repaired at the contractor's expense. Contractor shall respond on site to system problems within 24 hours.*

*All work shall be performed by a Contractor with a valid Oregon State Contractor's license for the installation of fire sprinkler systems.*

**Invitation to Bid  
DASPS-1473-18  
Solicitation Addendum No. 1**

---

*The field installation shall be supervised at all times by a journeyman sprinkler fitter or person with equivalent experience.*

=====

This Solicitation Addendum constitutes a MATERIAL CHANGE to the bid; and it MUST BE SIGNED AND RETURNED PRIOR TO THE BID CLOSING DATE AND TIME. ITS RECEIPT MUST ALSO BE ACKNOWLEDGED BY INSERTING ITS NUMBER ON THE APPROPRIATE BLANK LINES IN SECTION H OF THE BID DOCUMENT.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Bidder Name: \_\_\_\_\_  
(Please Print)